

Approval Number: 1902516
Test Report: MA6503/F



5th August 2019

Henkel Ltd.
Technologies House,
Wood Lane End,
Hemel Hempstead,
Herts
HP2 4RQ

Water Regulations Advisory Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

COATINGS, PAINTS & LININGS - SITE APPLIED PIPE AND FITTINGS COATINGS.

5042

'Loctite® SF 770™'. Site applied, clear cyanoacrylate primer. Apply as per manufacturer's technical data sheet 'reference 1.4' dated August 2014. Cure for 30 seconds@20°C. For use with water up to 85°C.

This material is only approved for the curing conditions that appear on the approval. If the cure conditions are varied from those specified on the approval then the material is not covered by the scope of the approval.

APPROVAL NUMBER: 1902516
APPROVAL HOLDER: HENKEL LTD.

The Scheme reserves the right to review approval.
Approval 1902516 is valid between February 2019 and February 2024

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory