

27th July 2018

Henkel Ltd.
Technologies House,
Wood Lane End,
Hemel Hempstead,
Herts
HP2 4RQ

Water Regulations Advisory Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

SEALANTS - SCREWED JOINTS - GENERAL.

5510

'Loctite® 55'. White coloured nylon cord coated with a silicone paste, intended for use as a thread sealant. The cord is to be applied and tightened in accordance with Technical Data Sheet 'reference 1.9', dated August 2016 and this material is only approved for these conditions. For use with water up to 85°C.

APPROVAL NUMBER: 1807518

APPROVAL HOLDER: HENKEL LTD.

The Scheme reserves the right to review approval.

Approval 1807518 is valid between .July 2018 and .July 2023