

Approval Number: 1901521  
Test Report: MA6000/1/W



15<sup>th</sup> February 2019

Henkel Ltd.  
Technologies House,  
Wood Lane End,  
Hemel Hempstead,  
Herts  
HP2 4RQ

Water Regulations Advisory Scheme Ltd.  
Unit 13,  
Willow Road,  
Pen y Fan Industrial Estate,  
Crumlin,  
Gwent,  
NP11 4EG

**WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)**  
**MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

**COATINGS, PAINTS & LININGS - FACTORY APPLIED PIPE & FITTINGS COATINGS.**

**5030**

'Loctite PC 7255 GN (Green) coating for use with Bonderite M-NT 1455-W primer'. Factory applied, green coloured, two-component epoxy resin coating. Prime the surface to be coated with the Bonderite primer wipe. Mix and apply as per manufacturer's TDS dated October 2016. Cure for 7 days@23°C. For use with water up to 85°C.

This material is only approved for the curing conditions that appear on the approval. If the cure conditions are varied from those specified on the approval then the material is not covered by the scope of the approval.

**APPROVAL NUMBER: 1901521**

**APPROVAL HOLDER: HENKEL LTD.**

The Scheme reserves the right to review approval.

Approval 1901521 is valid between January 2019 and January 2024

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: [www.wras.co.uk/directory](http://www.wras.co.uk/directory)