



DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NG-5146AR0620

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Henkel AG & Co. KGaA Gutenbergstraße 3, D-85748 Garching-Hochbrück
Distributor <i>Vertreiber</i>	Henkel AG & Co. KGaA Gutenbergstraße 3, D-85748 Garching-Hochbrück
Product Category <i>Produktart</i>	greasing and sealing materials: Sealing and jointing materials for screwed joint of gas appliances and gas plants, hardening (5146)
Product Description <i>Produktbezeichnung</i>	Anaerobic sealing material for metallic threaded joints in gas appliances, gas equipments and water heating equipments, not allowed in the gas installation according to DVGW-TRGI 2008
Model <i>Modell</i>	LOCTITE 511
Test Reports <i>Prüfberichte</i>	type testing: 11/294/5146/1 from 13.01.2012 (EBI)
Test Basis <i>Prüfgrundlagen</i>	DIN EN 751-1 (01.05.1997)

Date of Expiry / File No. 31.07.2016 / 11-0138-GNV
Ablaufdatum / Aktenzeichen

26.04.2012 Rie A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to EN 45011:1998 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN 45011:1998 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



DVGW CERT GmbH
Josef-Wirmer-Straße 1-3
53123 Bonn

Telefon: +49 228 91 88-888
Telefax: +49 228 91 88-993
eMail: info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
LOCTITE 511	class: H	for diameters >DN 10 up to DN 50

Hints of Utilization / Remarks***Verwendungshinweise / Bemerkungen***

suitable for: metallic threaded joints for use on rough threads
not allowed: in gas installations according to DVGW-TRGI 2008