

und -prüfung

Report

on Testing a adhesive for Reactivity with Oxygen

Reference Number

II-1002/2009 E

Copy

1. Copy of 2 Copies

Customer

Henkel AG & Co. KGaA

Gutenbergstraße 3 85748 Garching

Order Date

April 27, 2009

Reference

Order.-no.: 4591143881

Receipt of Order

April 30, 2009

Test Samples

Thread sealant LOCTITE® 271 TM for use in gaseous oxygen in valves and fittings or other components at temperatures up to 60 °C and for liquid oxygen service.

BAM-Order No. II.1/49 650

Receipt of Samples

April 30, 2009

Test Date

June 12, 2009 to July 16, 2009

Test Location

BAM-Working Group "Safe Handling of Oxygen"; building no. 41, room no. 120 and room no. 073

Test Procedure According to DIN EN 1797: 2002-02

"Cryogenic Vessels - Gas/Material Compatibility"

Annex of pamphlet M 034-1 (BGI 617-1)

"Liste der nichtmetallischen Materialien die von der Bundesanstalt für Materialforschung und –prüfung (BAM) zum Einsatz in Anlageteilen für Sauerstoff als geeignet

befunden worden sind.",

to pamphlet M 034 "Sauerstoff" (BGI 617) Berufsgenossenschaft der chemischen Industrie

Edition: October 2008;

according chapter 3.17 "Gleitmittel und Dichtwerkstoffe" to rule BGR 500 "Betreiben von Arbeitsmitteln" part 2, chapter 2.32 "Betreiben von Sauerstoffanlagen", Edition:

September 2008.

All pressures of the report are excess pressures.

This test report consists of page 1 to 4 and annex 1 and 2.

This test report may only be published in full and without any additions. A revocable permission in writing has to be obtained from BAM for any amended reproduction of this certificate or the publication of any excerpts. The test results refer exclusively to the tested materials.

In case a German version of the test report is available, exclusively the German version is binding.



1 Documents and Test Samples

The following documents and samples were submitted to BAM:

1 Test application

1 Safety Data Sheet

1 Technical Data Sheet

4 bottles Anaerobic adhesive LOCTITE® 271™

Threadlocker HIGH STRENGHT PART No. 27131

Volume per bottle: 50 ml

Red liquid

2 Test Methods and Results

The thread sealant LOCTITE® 271 TM has been tested in liquid and in cured condition.

A determination of the autogenous ignition temperature (AIT) and a test for aging resistance in high pressure oxygen were not necessary as LOCTITE® 271TM is not for use at temperatures greater than 60 °C.

2.1 Ignition Sensitivity to Gaseous Oxygen Impacts

The test method is described in annex 1.

2.1.1 Liquid Thread Sealant

Results:

| Sample temperature t _a [°C] | Oxygen pressure p _a [bar] | Oxygen pressure p _e [bar] | Reaction on Impact |
|--|---|---|--------------------------------|
| 60 | 1 | 20 | ignition on 2. impact |
| 60 | 1 | 15 | ignition on 3. impact |
| 60 60 | 1 1 | 10 10 | no reaction*) no reaction*) |

^{*)} within a series of five consecutive impacts

In two separate tests, each consisting of a series of five consecutive impacts, no reactions of the thread sealant LOCTITE[®] 271^{TM} with oxygen could be observed at an oxygen pressure p_e of 10 bar.

2.1.2 Cured Thread Sealant

Results:

| Reaction on Impact | Oxygen pressure p _e [bar] | Oxygen pressure p _a [bar] | Sample temperature t _a [°C] |
|--------------------------------|---|---|--|
| ignition on 1. impact | 25 | 1 | 60 |
| no reaction*) no reaction*) | 20 20 | 1 | 60 60 |

^{*)} within a series of five consecutive impacts

In two separate tests each consisting of a series of five consecutive impacts, no reactions of the thread sealant LOCTITE® 271 $^{\text{TM}}$ with oxygen could be observed at an oxygen pressure p_e of 20 bar.

2.2 Reactivity with Liquid Oxygen on Mechanical Impact

The test method is described in annex 2.

2.2.1 liquid thread sealant

Results:

| Test No. | Drop Heights [m] | Impact Energy [Nm] | Reaction |
|----------|---------------------|-----------------------|--------------------------|
| 1 | 0,17 | 125 | ignition on 1. impact |

At drop heights of 0,17m (impact energy 125 Nm), in the first test a intense reaction of the material with liquid oxygen could be detected.

BAM-Ref.: II-1002/2009 E

3 Summary and Evaluation

According to ISO 21010: 2004-04 "Cryogenic Vessels - Gas/Material Compatibility" the criterion for a positive reaction of a sample to gaseous oxygen impacts is a temperature rise of 20 K.

On basis of the above-mentioned criterion and the test results, there are no objections with regard to technical safety, to use the thread sealant LOCTITE® 271 TM in piping, valves and fittings, or other components for gaseous oxygen service at following operating conditions:

| Maximum Temperature | Maximum oxygen pressure |
|---------------------|-------------------------|
| 60 °C | 10 bar |

According to the BAM-Standard "Testing for Reactivity with Liquid Oxygen on Mechanical Impact", described in annex 2, the thread sealant LOCTITE® 271TM is not suitable for liquid oxygen service.

5 Comments

The test results refer exclusively to the tested material.

Products that have been tested by us, and which are on the market, shall be marked according to our evaluation in the BAM test report. A label on a product saying that a BAM test has been performed and (or) citing our reference number, only, is not tolerable. The use of the product and its safe operating conditions must also be given.

It shall be clear that the product may only be used for gaseous oxygen service. The maximum safe oxygen pressure of the product and its maximum use temperature as well as other restrictions in use shall be given.

BAM Federal Institute for Materials Research and Testing 12200 Berlin, July 29, 2009

Division II.1

"Gases, Gas Plants"

Working Group

"Safe Handling of Oxygen"

Dr. Chr. Binder

Head of Working Group

Dipl.-Ing. K. Arlt Engineer in Charge

Copies:

1. Copy: Henkel AG & Co. KGaA

2. Copy: BAM-Working Group "Safe Handling of Oxygen"

Annex 1

Testing for Ignition Sensitivity to Gaseous Oxygen Impacts

Approximately 0.2 g to 0.5 g of the pasty or divided solid sample is placed into a heatable steel tube, 15 cm³ in volume. In case of liquids to be tested, ceramic fibre, soaked with the sample, is used. The sample tube is connected by a 750 mm long pipe (internal diameter 14 mm) and a pneumatically operated quick opening valve to a high-pressure oxygen accumulator.

A heater allows to set the sample tube to the test temperature ta After the tube and pipe are at test pressure pa, the quick opening valve is opened and preheated oxygen of 60 °C and of pressure pe flows abruptly into the pipe and tube. In this way, the oxygen in the tube and in the pipe is almost adiabatically compressed from pressure pa to pe and heated. If there is a reaction of the sample with oxygen, indicated by a steep temperature rise in the tube, further tests with a new sample are performed at a lower pressure ratio p_e/p_a. If, however, no reaction of the sample with oxygen can be detected after a waiting period of 30 seconds, the tube is de-pressurized and the test is repeated (up to four times) until a reaction takes place. This means, each test series consists of a maximum of five single tests with the same material under the same conditions. If no reaction can be observed, even after the fifth single test of a test series, testing is continued with new samples at greater pressure ratios pe/pa, until finally that pressure ratio is determined, at which no reaction can be observed within a test series of five single tests. If the repetition of that test series with a new sample shows the same result, the test can be finished or continued at a different test temperature ta.

- Working Group "Safe Handling of Oxygen" -

Annex 2

Testing for Reactivity with Liquid Oxygen on Mechanical Impact

Approximately 0.5 g of the liquid or divided sample is placed into a sample cup (height = 10 mm; diameter = 30 mm), made of 0.01 mm copper foil. Liquid oxygen is poured into the cup over the sample which is then exposed to the mechanical impact of a plummet (mass = 76.5 kg). The drop height of the plummet can be varied. A steel anvil with a chrome/nickel steel plate supports the sample cup. The anvil, having a mass eight times of the plummet, is supported by four damping elements mounted on the steel frame of the test apparatus that rests on a concrete base.

A reaction of the sample with liquid oxygen is usually indicated by a flame and a more or less strong noise of an explosion. The impact energy, at which no reaction occurs, is determined in varying the drop height of the plummet. This result shall be confirmed in a series of ten consecutive tests under the same conditions. The tests are finished, if reactions can be observed at impact energies of 125 Nm or less (equivalent to a drop height of the plummet of 0.17 m or less). In this case, with regard to technical safety, the material is not suitable for liquid oxygen service.