

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NG-5146BL0338

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Henkel AG & Co. KGaA Gutenbergstraße 3, D-85748 Garching-Hochbrück
Distributor <i>Vertreiber</i>	Henkel Loctite (Ireland) Ltd. Talaght Busniss Park, Whitestown, IE- Tallaght, Dublin 24
Product Category <i>Produktart</i>	greasing and sealing materials: Sealing and jointing materials for screwed joint of gas appliances and gas plants, hardening (5146)
Product Description <i>Produktbezeichnung</i>	Anaerobic sealing material for metallic threaded joints in gas appliances, gas equipments and water heating equipments, not allowed in the gas installation according to DVGW-TRGI 2008
Model <i>Modell</i>	omniFIT seal 50H
Test Reports <i>Prüfberichte</i>	laboratory control test: 11/138/5146/03 from 10.08.2011 (EBI)
Test Basis <i>Prüfgrundlagen</i>	DIN EN 751-1 (01.05.1997)

Date of Expiry / File No. 09.08.2015 / 11-0138-GNV

Ablaufdatum / Aktenzeichen

06.10.2011 Rie A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to EN 45011:1998 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN 45011:1998 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.

Type	Technical Data	Remarks
Typ	Technische Daten	Bemerkungen
omniFIT seal 50H	class: H	for diameters >DN 10 up to DN 50

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

suitable for: metallic threaded joints for use on rough threads
not allowed: in gas installations according to DVGW-TRGI 2008