



# DIN-DVGW type examination certificate

## DIN-DVGW-Baumusterprüfzertifikat

**NG-5146AR0618**  
Registration Number  
Registriernummer

<b>Field of Application</b> <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
<b>Owner of Certificate</b> <i>Zertifikatinhaber</i>	Henkel AG & Co. KGaA Gutenbergstraße 3, D-85748 Garching-Hochbrück
<b>Distributor</b> <i>Vertreiber</i>	Henkel AG & Co. KGaA Gutenbergstraße 3, D-85748 Garching-Hochbrück
<b>Product Category</b> <i>Produktart</i>	greasing and sealing materials: Sealing and jointing materials for screwed joint of gas appliances and gas plants, hardening (5146)
<b>Product Description</b> <i>Produktbezeichnung</i>	Anaerobic sealing material for metallic threaded joints in gas appliances, gas equipments and water heating equipments, not allowed in the gas installation according to DVGW-TRGI 2008
<b>Model</b> <i>Modell</i>	LOCTITE 5331
<b>Test Reports</b> <i>Prüfberichte</i>	type testing: 11/294/5146/7 from 13.01.2012 (EBI)
<b>Test Basis</b> <i>Prüfgrundlagen</i>	DIN EN 751-1 (01.05.1997)

**Date of Expiry / File No.** 31.08.2016 / 11-0138-GNV  
*Ablaufdatum / Aktenzeichen*

26.04.2012 Rie A-1/2

Date, Issued by, Sireel, Head of Certification Body  
*Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle*

DVGW CERT GmbH is an accredited body by DAkkS according to EN 45011:1998 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN 45011:1998 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



DVGW CERT GmbH  
Josef-Wirmer-Straße 1-3  
53123 Bonn  
Telefon: +49 228 91 88-888  
Telefax: +49 228 91 88-993  
eMail: info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
LOCTITE 5331	class: H	for diameters >DN 10 up to DN 50

**Hints of Utilization / Remarks*****Verwendungshinweise / Bemerkungen***

suitable for: metallic threaded joints for use on rough threads  
not allowed: in gas installations according to DVGW-TRGI 2008