

Our Ref: CR/JC

10 May 2004

Henkel Loctite Adhesives Ltd
Watchmead
Welwyn Garden City
Herts
AL7 1JB

Dear Sir

WATER REGULATIONS ADVISORY SCHEME
"ITEMS WHICH HAVE PASSED FULL TESTS OF EFFECT ON WATER QUALITY - BS 6920"

We refer to your application for the material(s) described below to be approved arising from the results of the tests of effect on water quality that have been carried out on the product(s) so described, it has been decided that there is no objection to its/their use provided the source, nature and manufacturing processes of the ingredients and products are not changed. (See notes overleaf).

SEALANTS - FLAT FACED JOINTS - SILICONE

5500

Loctite 587. Blue coloured silicone sealant. Apply as per manufacturer's instructions. Cure 7 days at 7°C. For cold water and hot water use up to 85°C. For use only in undertakers service reservoirs or similar structures having been tested at reduced surface area.

Test Report: M103262

0403505

HENKEL LOCTITE ADHESIVES LTD

An entry, as above, will accordingly be included in the Water Fittings and Materials Directory, Part Two, under the section headed, "Materials which have passed full tests of effect on water quality".

Your attention is drawn to the statement overleaf. Manufacturers or applicants may only quote in their sales literature terms which are used in this letter, namely that the product as listed, having passed the tests of effect on water quality, is suitable for use in contact with potable water and that a reference to the product will be included in the Materials section, Part Two, of the Water Fittings and Materials Directory: this may be abbreviated to "Water Regulations Advisory Scheme - Approved Product" or "WRAS - Approved Product". **Approval of this product does not signify the approval of its mechanical or physical properties for any use.**

The Technical Committee of the Scheme reserves the right to review approval. This product automatically becomes due for audit reassessment in March 2009.

Yours faithfully



Chris Ramsey (Miss)
Materials Administrator
Water Regulations Advisory Scheme