

Approval Number: 1911504
Test Report: J-00339780



12th November 2019

Henkel Ltd.
Technologies House,
Wood Lane End,
Hemel Hempstead,
Herts
HP2 4RQ

Water Regulations Advisory Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

SEALANTS - SCREWED JOINTS - ANAEROBIC ADHESIVES. THESE PRODUCTS ARE TO BE APPLIED AND CURED IN STRICT ACCORDANCE WITH THE MANUFACTURER'S INSTRUCTIONS **5520**

'Loctite 2700'. Green coloured anaerobic adhesive. Apply as per manufacturer's technical data sheet reference '0.1', dated May 2009. For use with water up to 85°C.

These products are to be applied and cured in strict accordance with the manufacturer's instructions

APPROVAL NUMBER: 1911504
APPROVAL HOLDER: HENKEL LTD.

The Scheme reserves the right to review approval.
Approval 1911504 is valid between November 2019 and November 2024

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory