

## DG TYPE EXAMINATION CERTIFICATE

No.  
DG-3415

This is to certify that:

Danish Institute of Fire and Security Technology, specified as a "notified body" under the terms of the Danish Safety Technology Authority, did undertake the relevant type approval procedures for the equipment identified below which was found to be in compliance with the Danish Gas Regulations, Section C-2, subject to any conditions in the description attached hereto.

**Applicant** Henkel Denmark A/S  
**Address** Industriparken 21A, DK-2750 Ballerup, Denmark  
**Type of Appliance** Hardening thread seal  
**Trade Mark** Loctite  
**Type/Model** 577  
**Specified Standards** EN 751-1:1996

**The attached (*description of type approval*) forms part of this certificate.  
This certificate remains valid unless cancelled or revoked, provided the conditions in the attached schedule are complied with and the equipment remains satisfactory in service.**

Date of issue 2017-05-22 Issued by Danish Institute of Fire and Security Technology  
Notified Body No. **0845**

Signed



Name

Ken Olesen

Note:

**This certificate will not be valid if the manufacturer makes any changes or modifications to the approved equipment, which have not been notified to, and agreed with the notified body named on this certificate.**



–XXXX

Subject to compliance with the conditions in the annex "Description of Type Approval", which forms part of this certificate, and those of the Regulations, the Manufacturer is allowed to affix the "Mark of Conformity" to the product described herein.

xxxx DG approval number

**This certificate is issued under the authority of the Danish Safety Technology Authority.**



(Annex)  
**Description of Type Approval**

## Product Description

**Trade Marks** Loctite  
**Type/Model** 577

## Technical Data

**Category:** III  
**Max. pressure** 4 bar  
**Max. temperature:** +80°C

**Comments:** Only for use on factory fitted components, not intended for subsequent disassembly.

## Type Approval Documentation

**Approval certificate No. :** DVGW Type Examination Certificate no NG-5146CQ0312 dated 2015-11-19 regarding compliance with EN751:1996

**Others:** Teknisk Datablad "LOCTITE® 577™" January 2016

**End of Certificate**